

~~RESTRICTED~~

Elmer General

405914

R

884

S. P. Howell

David L. Harver, Jr. POL By Pass - Elmer

January 20, 1953

DN
WSP

The enclosed is a partial reproduction of P.S. 693 (As-Built).

According to C. W. Kelley, you could pump diesel and gasoline at the same time. If this is so, how did you prevent interflow through the flanged coupling, immediately beyond the first incoming valves, that connects the two incoming pipes.

David L. Harver, Jr.
Chief Project Engineer

DLNjr:cas
Enc. (1)

cc: JS Chrono
Constr.-Oper. Div.
Project Engineering File ✓
Engineering File
815 Mail Room (2)

BEST COPY AVAILABLE

REPOSITORY NATIONAL ARCHIVES
PACIFIC SOUTHWEST REGION
COLLECTION RG 326 ATOMIC ENERGY COMMISSION
BOX No. 199624 (#608) A16334 326-65V0170
ELMER GENERAL
FOLDER JOB 834 PROJECT ENGINEERING FILE

"This material contains information affecting the national defense of the United States within the meaning of the espionage laws, Title 18, U.S.C., Secs. 793 and 794, the transmission or revelation of which in any manner to an unauthorized person is prohibited by law."

POL

DEPARTMENT OF ENERGY DECLASSIFICATION REVIEW	
DATE REVIEWED: <u>7/23/94</u>	DETERMINATION (CIRCLE NUMBER(S))
REVIEWED BY: <i>[Signature]</i>	1. CLASSIFICATION RETAINED
NAME: <i>[Signature]</i>	2. CLASSIFICATION CHANGED TO: _____
DATE: <u>7/23/94</u>	3. CONTAINS NO DOE CLASSIFIED INFO
	4. COORDINATE WITH: _____
	5. CLASSIFICATION CANCELLED
	6. CLASSIFIED INFO BRACKETED

~~SECURITY INFORMATION~~

~~RESTRICTED~~