

40627B

SF02

RR UWFJA

DE UHPJ 33

T LA254

R 022246Z

AEC GR243

DEPARTMENT OF ENERGY
CLASSIFICATION REVIEW

NAME: *William*
DATE: *7/28/94*

1. CLASSIFICATION (GAPLE NUMBER)
2. CLASSIFICATION RETAINED
3. CLASSIFICATION CHANGED TO
4. COORDINATE WITH
5. CLASSIFICATION CANCELLED
6. CLASSIFIED INFO BRACKETED

RECEIVED

SECURITY INFORMATION
RESTRICTED

EXEC VICE PRES	
V PRES & GEN MGR	
CH FISCAL OFFCR	
ASST GEN MGR	I
OPER-CONS!	I
INDUS RELATIONS	
PROCUREMENT	
ESTIMATING	
OFFICE MANAGER	
DIR OF ENGRNG	
CH DESIGN ENGR	
CH PRODUCE ENGR	I
PROJ ENGR (E&P)	I
SALES MGR	
ACCOUNTING	
SECURITY	

BEST COPY AVAILABLE

FROM HOW NAN ENIWETOK
TO HOW NAN LOSA

Survey

This material contains information affecting the national defense of the United States within the meaning of the espionage laws, Title 18, U.S.C., Secs. 793 and 794, the transmission or revelation of which in any manner to an unauthorized person is prohibited by law.

~~RESTRICTED~~

ACTION

CITE ENHMSG TWO NINE THREE ZERO

DAVE NARVER JR FROM BOETTCHE PD REF HOW NAN EIGHT FOUR FOUR ZERO

VISUAL INSPECTION OF SOIL AT ELEVATION PLUS FOUR ON STATION ONE TWO ZERO ZERO SITE SHOWS MATERIAL TO BE ONLY LOOSELY COMPACTED CMM COARSE GRANULAR CORAL SAND PD THREE TO FOUR FOOT VERTICAL FACE OF CUT ON SIDES OF EXCAVATION REVEALS THIS MATERIAL ABOVE FOOTINGS TO CONTAIN SEVERAL ONE TO TWO INCH THICK LENSES OF LIGHTLY CEMENTED CORAL PEA GRAVEL PD STEEL RODS DRIVEN TWO FEET ENCOUNTER NO SOLID CORAL BASE PD PARA PERSONALLY QUESTION WHETHER FULL FOUR ZERO ZERO ZERO PETER SUGAR FOX CAN BE DEVELOPED HERE PD HOWEVER CMM REALIZING THIS MAXIMUM PROBABLY ONLY

REQUIRED UNDER TOES OF RETAINING WALLS CMM HAVE AGREED NOT REQUEST BEARING TEST ACCOUNT DOUBTFUL VALUE AND TO AVOID DELAYING FORMING AND

REINFORCING OF FOOTINGS FOR STATION ITSELF NOW UNDERWAY PD PARA REQUEST YOUR ADVICE CMM PARTICULARLY SINCE FILE MEMO TWO ONE TWO SEVEN INDICATES

HEIGHT OF WALLS BEING REDUCED CMM WHICH MAY REDUCE BEARING REQUIREMENTS PD PARA FOR YOUR INFO CMM BEARING CONDITIONS STATION ONE TWO ZERO ZERO ONLY SLIGHTLY INFERIOR TO STATION TWO TWO ZERO ONE WHICH NOT

CONSIDERED CRITIC

L BECAUSE EXISTING ROOMS ABLE AND BAKER SATISFACTORILY

PDS HOWEVER CMM DESIGN SOIL PRESSURE THESE ROOMS NOT AVAILABLE AT JOBSITE FOR COMPARISON

02/2259Z

LJ

SECURITY INFORMATION
RESTRICTED 2930

NATIONAL ARCHIVES
REPOSITORY PACIFIC SOUTHWEST REGION
COLLECTION RG 326 ATOMIC ENERGY COMMISSION
BOX No. 199624 (#608) A16334 326-65V0170
SURVEYS
FOLDER AUGUST 1, 1953 ON