


RG 326 US ATOMIC ENERGY  
 COMMISSION F-23  
 Location LANL B-195  
 H 017  
 Collection Records Center  
 Folder REDWING MAN LOG  
OF ENVIR. FALLOUT



COPIED/DOE  
 LANL RC

Source

$$2.22 \times 10^5$$

$$6.57 \times 10^5$$

$$1.11 \times 10^6$$

EFFICIENCY (%)

$$11.25 - 10.45$$

$$9.72 - 7.65$$

$$7.76 - .06$$

The above figures were arrived at by using a scaler to count monitor's pulse shaped but unintegrated output. No attempt to show coincidence loss etc. was made.

### Conversion Factor

$$\begin{aligned} d/m/\text{meter}^3 &= (\text{net count}) \left( \frac{1}{\text{eff}} \right) \left( \frac{1}{\text{ft}^3} \right) \left( \frac{\text{ft}^3}{\text{m}^3} \right) \\ &= c/m \times d/c \times \frac{1}{\text{ft}^3} \times \frac{\text{ft}^3}{\text{m}^3} \\ &= c/m (8.9) (1/2.7) \times 34.3 \\ &= c/m (113) \end{aligned}$$

It is felt however that the efficiency is considerably higher at low levels than indicated, a conversion factor of 75 was used in all work.

the resolution time of the instrument at a tape speed of one foot per hour is about 12 minutes. Many of the 'spikes' appearing on the records were undoubtedly caused by one or two hot particles. Filter tape cutting proved this to be true in a small number of cases checked.

There is also a lag of from 20-30 minutes @ 1 ft/hr. filter speed between sampling time and counting. In high level cases the rise in back ground may signal the operator to increase the tape speed and shorten the time lag.

I  
J  
K  
L  
M  
N  
O  
P  
Q  
R  
S  
T  
U  
V  
W  
Y  
Z

AIR MONITOR

Recommendations

- a. Size
- b. Weight
- c. Filter rewind clutch (redesign)
- d. Overload protection for the main drive transmission.
- e. Hinged doors rather than snap on fasteners.
- f. Scale selector for remote operation.
- g. The original logarithmic amplifier?
- h. Possibility of using short, end window detector tubes - Anton Lab #100IT  
(low background & reduction of pig size)
- i. Future units to record background level (mr./hr.)
- j. Pump oiling requirements every 2 days - not satisfactory for field use.
- k. Laboratory determination of the unit's physical constants and incorporation  
of the data into the instruction manual - detector efficiency, number of  
cubic feet of air whose residue is seen by the detector etc.
- l. More light in the pump compartment.
- m. Brass stack locking nut unsatisfactory due to corrosion.

n - External plugs w/ recorder

o - weather shield w/ filter screen

The size and weight of the present air monitors is very unhandy for field use. The necessity of oiling every two days is also not suited to a unit which may be removed in the field. The filter tape rewind clutch does not work well and mechanical over load protection should be provided for the drive transmission. The Anton Laboratory 100-IT alpha-beta tubes claim low background and due to their small length to diameter ratio would reduce the pig size considerably. It is hoped that the logarithmic amplifier originally planned for the monitors may be incorporated - if not then remote scale selection is necessary.

M  
N  
O  
P  
Q  
R  
S  
T  
U  
V  
W  
Y

It was noticed toward the end of the operational period that rain was of ten followed by periods of fall out. Rain information was obtained from the weather station on Fred. How closely the start and stop times coincide for the two islands is not known. Cases of coincidence are shown on the summary at the front of the record and covered more carefully at the rear.

No record of rainfall has been procured for Bikini Atoll

After procurement of the data it was noted that both the amount of data and accuracy of readings did not lead themselves to a detailed correlation. It is not difficult to conjecture that if various layers of air above us are somewhat active - that rain will or perhaps will bring a certain amount of it down - It is believed that that may be taken as conclusion for this brief attempt. The data is enclosed hoping that further information may prove useful.

Q  
R  
S  
T  
U  
V  
W  
Y  
Z

# NAN

Time base

- 2 divisions per hour

Scale

- reads directly in counts per minute Times the scale factor

range      Scale factor.

1K - X 100

10K - X 1000

100K - X 10,000

The small conversion rule to be found at the beginning of this record will enable quick conversion to  $d/m/m^3$  using a factor of 75. (Discussed earlier)

2210

AVERAGE BACKGROUND

29 MAY + 1300 TO 2300  
100 c.p.m.

4.5

1740  
- 430  
2210

← 200 c.p.m.  
1900 MAY 29

1790

← 1700 29 MAY 1710

← 1625 29 MAY

← 1400 29 MAY

← 1530 29 MAY

1500

1445

1430

1345

← 1315

1245

1130 29 MAY


COPIED/DOE  
LANL RC

1030

← 945 AM 29 MAY

945 AM 29 MAY

for meeting  
with Alan  
White etc



Operation began:

Elmer sampler	-	24 May 1956	E
Aunsworth "	-	29 May 1956	F
Sta. # 70 "	-	29 May 1956	G

All three units were calibrated at the shop (Elmer) before being put in operation. A calibration chart will be found in the rear of this record. The units were found to be quite linear for evenly spaced pulses.

The following may be used to calculate the number of cubic feet of air whose residue is seen by the detector at any given time.

$$N = 3.06 \frac{A}{B}$$


where:

N = number of cubic feet

A = air flow rate, ft<sup>3</sup>/minute

B = filter paper speed, ft/hour

Detector efficiency values taken using the sources supplied with the unit follow.




BACKGRO  
 NO COUNT  
 AFTER  
 MONITOR  
 MAY 30  
 WARM U  
 1355 T

BACKGROUNDS 12:00 P.M.

RAIN BEGIN  
 30 MAY  
 55

NO COUNT



NO. 600006 ISSUED BY MONTGOMERY CO. PHILA.

12

MADE IN U.S.A.

11:00 AM

1:30 P.M.

11:40 AM 2:00 P.M.

12:10 PM 1 June

Highway

~~12:10 PM~~  
12:18

1:30 P.M.  
1:55 JUNE 1

1:40 P.M.  
1:41 JUNE 1

1:30 JUNE 1

5:50 P.M.  
1:10 JUNE 1

2:30 JUNE 1

OB

Y. S. U. S. B. S. I. N. I. T. I. O. N.

Y. S. U. S. B. S. I. N. I. T. I. O. N.

NO. 600006 RESEARCH INSTRUMENTS CO. ANAL.

0730 JUNE 2

0710 JUNE 2

0845 AM 2 June  
146 P.M. 0855

340 P.M. 1405 JUNE 2

140 C.P.M. 1330 JUNE 2


1500 JUNE 2

560 C.P.M. 1606 JUNE 2

COPIED/D  
LANL RC

10m

17 00 00



NO. 600006

LESTER & NORTHROP CO. PHILA.

← 340 P.M. 07.05 JUNE 3

← 0315 JUNE 3

← 200 P.M. 0115 JUNE 3


1 on

ks

f

BACKGROUND - 70 C.P.M.

1901 140 C.P.M.




COPIED/DOE

16

BACKGROUND - 60 C.P.M.


NO COUNTS ABOVE BACKGROUND



LAWL RG

BACKGROUND - 60 c.p.m.

1332 120 c.p.m.




COPIED/DOE  
LANL RC

NO. 60009 ON

BACKGROUND - 55 C.P.M.

NO COUNTS ABOVE BACKGROUND




COPIED BY  
LANL RC

10

9 JUNE 1956 23

BACKGROUND - 50 C.P.M.

NO COUNTS ABOVE BACKGROUND.




†

20

BACKGROUND - 50 C.P.M.

1652 80 e.p.m.



COPIED/DOE  
LANL RC


21

BACKGROUND - 40 C.P.M.

1355

280 C.P.M. (CHECK GRAPH)


(they have been automatic recorder balance)



12 JUNE 1956 29

BACKGROUND - 40 C.P.M.

NO COUNTS ABOVE BACKGROUND.



COPIED/DOE  
LANL RG

ab #10


old use

corpor

number

en bre

23




NO. 600003 LITGA & NORTON CO. PHILA.

OTT  
ration  
of  
peaks

COPIED/DOE  
LAN/RC

24


14 JUNE 1956 33



PHILIP M. GARDNER, JR. & NORTHROP CO. PHILA.

ORT  
ation  
of  
peaks

25




on

4115

BACKGROUND - 70 C.P.M.

NO COUNTS ABOVE BACKGROUND.

MONITOR WAS TURNED  
OFF AT 1500 JUNE 16  
TO 0845 JUNE 17.




COPIED/DOE  
LANL RC.

BACKGROUND - 60 C.P.M.

0845 MONITOR WARM UP FOR 45 MINUTES

1641 230 C.P.M.

1720 160 C.P.M.




B-4

2  
28

COPIED/DOE  
IANL RC

BACKGROUND - 60 C.P.M.

NO COUNTS ABOVE BACKGROUND



Position  
of  
marks

050


APR 1965  
MIL CO











130 23 June

NO. 60006 (1978 & 1979)

MADE IN U.S.A.

lon

ks

34

COPIED/DGE  
LANL RG







29 June 59


COPIED/DOE  
LANL RC

38

28 June 61

COPIED/DOE  
LAWL RG

39





NO. 874500

1525 2 JULY

30  
47  
100

45





4 July 73


COPIED/BGF  
LANL RC

45




















12 July 89



COPIED/DOE  
LANL RC

55







16 July 97

MADE IN U.S.A.

50	40	30	20	10	0	10	20	30	40	50
WARM UP Period ↑										
Machine - trouble - drive										
of car										

10006 4785 8 NORTHUP CO. PHILA.

COPIED/DOE  
LANGRIS

59






19 July

103

DEKORATIVE CO. PHILA.

†

COPYED/DOE  
LAIN 30



1

105

21 July 107

The image shows a large grid table with a central vertical strip. The grid is composed of horizontal and vertical lines forming a series of cells. The central strip is narrower than the other columns and contains a dense, dark, vertical pattern of lines. To the right of the grid, there is a handwritten number '6c'.

COPIED/DOE  
LANL RG ✓





24 July

113

The image shows a large grid table with approximately 10 columns and 30 rows. The grid is mostly empty, with some faint markings. In the center-left area, there is a smaller, vertically oriented grid with about 2 columns and 20 rows. The bottom of this smaller grid is filled with dark, vertical lines, possibly representing data or a scan artifact.

COPIED/DQE  
LANL RC ✓


61



CONV FLOW + T

4 S

↓ Typical warm up pattern



1495

16 June

hour on

← speed shift

Fall out

COPIED/OOE  
LANE RC

1045 16 June

109

#1

Typical Source  
backgrounds during  
the earlier portion  
of the operation  
D & R Curie →

COPIE 700E  
LANL

J-Div 287 curie



located about 120 yds  
North east.

D&R or ESL -

COPYDDE  
LANL RC ✓

11

24 may (Start -) 1675, 1730, 2000  
25 may 2100

APPR 11 AM May 25  
0100 25 MAY

MAX  $8.2 \times 10^4$  d/m<sup>3</sup>

APPR 2000 24 MAY

APPR 7:30 PM 24 May  
1930 24 MAY

wind up

1625 24 MAY

operate

28 may - 1230 thru 2300


0710 29 MAY 56

0710 29 MAY 56


2 7 5 1 2 3 5 1 2 3 5 1 2 3 5

2 3 5 1 2 3 5 1 2 3 5 1 2 3 5 1

2400 28 MAY 56



COPIED BY  
 LARL RC



0710.28 May 56

75

COPIED/DOE  
LANL RC

27 may 0130



— Rain 0219 - 0223

officer 0130 27 MAY

0130 27 MAY

MAX  $1.87 \times 10^4$  d/m/m<sup>3</sup>

76



1930 29 MAY

1550 29 MAY

MAX  $2.4 \times 10^4$  d/m/m<sup>3</sup>



15

0710 29 May 56

0710 29 MAY 56

COPIED/DOE  
LANL RC

78



1215 30 MAY

MAX  $1.95 \times 10^4$  d/m/m<sup>3</sup>

COPIED FROM  
LANL RC

79

30 May 1600 thru 2330

1330 30 MAY

1330 - 30 May 1954

COPIES  
LANL RG

— Rain 2050

MAX.  $695 \times 10^9$   
d/m/m<sup>3</sup>

COPYED/DOE  
LANA RG

0630 31 MAY 56

— Rain

Sound  
10/1


1230 1 June

COPIES/38  
LAWL RC

1 June

82

17 June 0820 line 1230  
2200 line 2300



0820/00E

83

8 June 1345, 1530 thru 1630

MAX.  $1.5 \times 10^4$  d/m/m<sup>3</sup>  
Ram

1345 8 June

COPIED/DOE  
LANL RC

84

58

COPIED FROM  
LAMP NO.

MAX.  $3.38 \times 10^5$   $\mu\text{m}^2$

— nam

↑ 27 June

↓ 26 June

← approx 2230 26 June

10K Scale

← EQUIPMENT FAILURE approx 830 PM - 900 PM

1K Scale

1K scale 745 PM 26 June

10K Scale

10K scale 645 PM 26 June

1K Scale

source  
DGR

17 July 0900

← 1030 17 July


— Rain  
0900 17 July  
MAX  $1.5 \times 10^3$  d/m/m<sup>3</sup>

U.S. GOVERNMENT PRINTING OFFICE: 1964 O - 300-006

MADE IN U.S.A.

CORLETT/DOE  
LANL RC

87



rain

MAX  $1.12 \times 10^5$  d/m/m<sup>3</sup>

0895 - 10K scale

~~0895 - 10K scale~~

0807 9 July

9 July

SS

Scale X10

1500 11 July 1500 11 July

INVALID



89

COPIES

NO.

NO. 600008 U.S.G. & BUREAU OF REVENUE CO. PHILA.

COPIED/DOE  
LANL RG

MAX  $3.75 \times 10^{25}$  d/m<sup>2</sup>



Rains following heavy fall out 24 July.

Rain #1 2100 23 July -  $5.5 \times 10^7$  d/m<sup>3</sup>

Rain #2 2230 23 July -  $4.04 \times 10^6$  d/m<sup>3</sup>

Rain #3 0720 24 July -  $3.6 \times 10^4$  d/m<sup>3</sup>

2300 sample down 33% 0720 #1  
 $\frac{1}{2}$  life 14  $\frac{1}{2}$  hrs appx.

Rain #4 0900 24 July -  $4.06 \times 10^4$  d/m<sup>3</sup>

COPIED/DOE  
LANL RC

90

Turn on 10K Scale 4 ft/m  
Tape speed 1030 22 July

← Shut OFF 1840

After tape not op.  
← gamma background

I 1515


21 July

COPIED/BOE  
LAWLER

D & R Source  
1145 21 July

913





95

COPIED/DOE  
 LANL RG

96

AIR MONITOR

Recommendations

- ✓ a. Size
- ✓ b. Weight
- ✓ c. Filter rewind clutch (redesign)
- ✓ d. Overload protection for the main drive transmission.
- ✓ e. Hinged doors rather than snap on fasteners.
- ✓ f. Scale selector for remote operation.
- ✓ g. The original logarithmic amplifier?
- ✓ h. Possibility of using short, end window detector tubes - Anton Lab #100IT  
(low background & reduction of pig size)
- ✓ i. Future units to record background level (mr./hr.)
- ✓ j. Pump oiling requirements every 2 days - not satisfactory for field use.
- ✓ k. Laboratory determination of the unit's physical constants and incorporation of the data into the instruction manual - detector efficiency, number of cubic feet of air whose residue is seen by the detector etc.
- ✓ l. More light in the pump compartment.
- ✓ m. Brass stack locking nut unsatisfactory due to corrosion.
- ✓ n. External plugs for remote hook up including the recorder.
- ✓ o. Weather shield and filter screen for intake stack (bug intake often breaks the tape)

Monitor all 3 prior to shipment to E.

COPIED/DOE  
LANI RC

Lb

DENSITOMETER

Recommendations

- (1) Light port in front
- (2) Larger zero knob
- (3) Badge holder that remains attached to unit.
- (4) #3 - Possibility of a feed through holder for continuous or automatic process
- (5) Range selection - (0 - 1 full scale)
- (6) Black on white read out register.
- (7) Proper ventilation for projector lamp. (180°F-145°F)
- (8) Possible use of concentrated arc lamp to accomplish #9.
- (9) Reduction of hunting and over shoot.
- (10) Parts mounted on power switches subject to damage in shipment.
- (11) Mirror alignment difficult.
- (12) Set screws in mechanical section often come loose and fall out.
- (13) Zero adjust drive alignment subject to shipping troubles.
- (14) Possibility of dynode by-pass capacitors as noise reduction measure.
- (15) Drive speed & stability characteristics drift considerably on a weekly basis requiring frequent adjustment.
- (16) Present badge holders warp and often break directly behind the badge slot

CCP/DOE  
LANL RG

86

INTEGRON

These instruments were used little due to several factors.

(1) It was difficult due to time restrictions to advertise and acquaint personnel with their operation and usefulness.

(2) Personnel generally dislike hauling around an extra piece of equipment, especially in hot areas where speed is necessary. The pocket dosimeter often provide enough information for the needs of the party.

Upon arrival only four units were operable. The relatively heavy warning system batteries are not adequately supported causing the whole chassis structure to bend. Chamber plug damage during shipping resulted. Moisture sensitivity noticed; it was however not of a really serious nature. Calibration was done every month with 20 - 25% corrections necessary.

The future usefulness of the integron will depend upon creating a need for such an instrument amongst project leaders etc.

COPIED/DOE  
LANL RC

bb

THYAC (ALPHA CONVERTED)


The converted thyac with circuit changes to increase the trigger period and integration constant seems to be a very good field unit. It has not shown itself to be moisture or temperature sensitive. The probe must be handled gently and a rather high photo multiplier mortality rate has been noted. A guard ring should be added as further protection of the very thin mylar window. The probe may be used for short periods of time in any desired position due to the high viscosity of the silicone coupling compound and shape of its cavity in the light pipe.

The unit is capable of calibration to provide  $4\pi$  readings with reasonable accuracy. Due to our lack of range in alpha sources they have only been checked at 400, 1800, 8800 and 3320 d/m. †

99

COPIES/DOE  
LANL RC

100



Shanghai  
 Rejection  
 MODIFIED THYAC 389

FOR USE WITH ALPHA SCINTILLATION PROBE



DRAWN BY LHT INST. REPAIR, AT RSU

100

100

181  
RESISTANCE CALIBRATION OF AN-PDR-39's

The T1-B or PDR-39 instruments rely on the accuracy of their hi-meg or chamber load resistances for scale decading. A single calibration control (meter series resistance) performs calibration of all scales at once.

It was felt that some method of assuring hi-meg accuracy should be used to check all instruments before they met field use. It was also felt that the Victoreen deposited carbon hi-meg resistances might be highly voltage sensitive and should be checked under circumstances approximating their actual operating potentials. Commercial hi-meg ohm meters often use potentials up to 1000 volts making them unsuitable for this application. An Applied Physics Corp. vibration reed electrometer was used to measure the potential across a 100 megohm standard resistance (calibrated to value  $\pm .3\%$ ) in series with the unknown hi-meg (in place in the instrument). All resistors varying more than 5% were replaced. No attempt to calibrate the 0 to 5 mr. range was made.

The standard Bendix bridge and sub miniature tube tester<sup>supplied</sup> by the Army for use with the instruments uses a potential of 16 volts across the unknown resistance. It is felt that the Bendix unit serves the purpose well - better perhaps than the electrometer technique which is of a laboratory nature.

For most accurate results each instrument should be calibrated on the scale representing the mean deviation (since each scale varies  $\pm$  a few percent). Time was not available for this purpose. Each T1-B carries within it a card giving the deviations for future use.

The PDR-39 schematic places the 5 mr and 50 mr scales in parallel. This results in a 10% deviation (low) it was noticed however that the 10% deviation was not always forthcoming when the instrument was radiation calibrated. Further study should reveal use-ful characteristic information.


The deviation percentage given on the cards in the instruments pertains to scale error when radiation is read.

COPIED/DOE  
LANL RC

COPYED/DOE  
LAWL RB

d/m/r  
x 1000

d/m/r  
x 100



Line #1 - airborne  
Line #2 - ground level  
Line #3 - 28 feet above #1

Back ground

July	21	22	23	24	25	26
0600	2.0	2.0	2.0	2.0	2.0	2.0
0700	2.0	2.0	2.0	2.0	2.0	2.0
0800	2.0	2.0	2.0	2.0	2.0	2.0

1600 1800 2100 2200 2300 2400 2500 2600 2700 2800 2900 3000 3100 3200 3300 3400 3500 3600 3700 3800 3900 4000 4100 4200 4300 4400 4500 4600 4700 4800 4900 5000 5100 5200 5300 5400 5500 5600 5700 5800 5900 6000 6100 6200 6300 6400 6500 6600 6700 6800 6900 7000 7100 7200 7300 7400 7500 7600 7700 7800 7900 8000 8100 8200 8300 8400 8500 8600 8700 8800 8900 9000 9100 9200 9300 9400 9500 9600 9700 9800 9900 10000

107