


SENT



PRESIDENT	
EXEC VICE PRES	
V PRES & GEN MGR	
CH FISCAL OFFCR	
ASST GEN MGR	1
OPER-CONST	2
INDUS RELATIONS	
PROCUREMENT	
ESTIMATING	
OFFICE MANAGER	
DIR OF ENGRNG	
CH DESIGN ENGR	
CH PROJECT ENGR	1
PROJ. ENGR	1
SALES DIVISION	
ACCOUNTING	
SECURITY	

HN-1

RR UHPJ

DE LA254/UWFJAX 50

R 181655Z

AEC GR138

SECURITY INFORMATION  
RESTRICTED

This material contains information affecting the national defense of the United States within the meaning of the Espionage Laws, Title 18, U.S.C., Secs. 793 and 794, the transmission or revelation of which in any manner to an unauthorized person is prohibited by law.

PAREN RESTRICTED PAREN SECURITY INFORMATION PD FROM HOW NAN LOSA PASS TO HOW NAN ENIWETOK PD HOW NAN EIGHT EIGHT SEVEN NINE PD BOETTCHER FROM DAVE NARVER JR PD REURMSG THREE TWO SIX SIX PD THICKNESS OF FIRST FLOOR WALL SHOWN ON DWG SIX THREE TWO FIVE CMM RIGHT HAND SIDE OF SECTION DOG SHOULD BE SIX FEET PD STEEL IN EACH FACE SHOULD BE NR NINE AT ONE ZERO VERTICAL AND NR EIGHT AT ONE ZERO HORIZONTAL PARA SIMULTANEOUS POURING OF LIMONITE FRONT WALL AND REGULAR CONCRETE SIDE WALLS TO ELIMINATE COLD JOINT IS PERMITTED CMM PROVIDED THAT THE THICKNESS OF THE LIMONITE SPECIFIED ON THE DWG IS NOT REDUCED BY DIFFUSION OF THE REGULAR CONCRETE POUR INTO THE LIMONITE PARA DWG SIX TWO SIX ONE NO LONGER APPLIES TO STATION TWO THREE ZERO ZERO PD

18/1718Z

DEPARTMENT OF ENERGY

SINGLE REVIEW APPROVED BY

REVIEWER NAME: *D. L. [unclear]*

REVIEWER TITLE: *12/11/54*

DATE: *2/1/54*

RESTRICTED