

Resident Engineer JS 884

David L. Narver, Jr. Warehouse Building 61, Tare

October 28, 1953

R
DR

The following is quoted from LASL letter J-21048 dated October 23, 1953 and is forwarded to you for action:

"Electrical requirements for Warehouse Building 61, Tare, are as follows. Lighting shall be provided by five lights, with metal reflectors, hung at 10' intervals along the ridge with a clearance of 12' above the floor. One wall switch is required. Two 15 amp duplex convenience outlets are required, one at either end of the building.

At present, the user does not require any necessity for shelving in the warehouse."

DLNJr: eas

David L. Narver, Jr.
Chief Project Engineer

cc: Project Manager JS
Constr.-Oper. Div. (2)
C. L. East
Project Engineering File ✓
751 Mail Room (2)

DEPARTMENT OF ENERGY DECLASSIFICATION REVIEW	
SINGLE REVIEW AUTHORIZED BY <i>A.A. Sinigaglia 7-23-94</i>	DETERMINATION (CIRCLE NUMBER) 1. CLASSIFICATION REQUIRED 2. CLASSIFICATION EXEMPT 3. CONTAINS UNCLASSIFIED INFO 4. COORDINATE WITH 5. CLASSIFICATION REVIEW 6. CLASSIFIED INFO REVIEW
REVIEWER (ADD) <i>J.D. Lazen</i>	
NAME <i>J.D. Lazen</i>	
DATE <i>7/29/94</i>	