

HN-02  
RR UHPJC

DE LA254/UWLJAX 78

R 262147Z

AEC GRNC

REPOSITORY \_\_\_\_\_  
 COLLECTION \_\_\_\_\_  
 BOX NO. \_\_\_\_\_  
 FOLDER \_\_\_\_\_

R

PRESIDENT	
EXHIBIT	
V.F.	
DATE	
BY	
INITIALS	
REMARKS	
SEARCHED	
SERIALIZED	
INDEXED	
FILED	

884  
 Kals

FROM HOW NAN LOSA  
 TO HOW NAN ENIWETOK

~~/RESTRICTED/ SECURITY INFORMATION~~

HOW NAN NINE SEVEN SIX FOUR PD  
 DIETZE FROM DAVE NARVER JR PD RE STATION ONE TWO ONE ZERO DOG CMM REF  
 DWG SIX TWO FOUR NINE CMM SIX TWO THREE EIGHT AND SIX TWO ONE EIGHT PD  
 CLEAR HEIGHT OF TYPE NINE DOOR OPENING SHOWN ON DWG SIX TWO FOUR NINE  
 AND DWG SIX TWO THREE EIGHT SECTION ABLE MUST BE INCREASED FROM SEVEN  
 FEET NINE INCHES TO EIGHT FEET TWO INCHES PD FIELD SPLICE THE EIGHT  
 BY SIX BY FIVE SLASH EIGHT DOOR FRAME ANGLES SHOWN ON DWG SIX TWO ONE  
 EIGHT AT A POINT ABOVE THE TOP HINGE TO GIVE THE REQUIRED FIVE INCH  
 EXTRA HEIGHT PD SKETCH SHOWING REQUIRED FIELD REWORK OF TYPE NINE DOOR  
 WILL FOLLOW PD

B. [Signature]  
 of which in any  
 prohibited by law.

1210

DEPARTMENT OF ENERGY DECLASSIFICATION REVIEW	
SINGLE REVIEW AUTHORIZED BY: AASimigall 7-27-94	(1) INFORMATION FORCIB NUMBER
REVIEWER (ADD):	(2) CLASSIFICATION REMAINS
NAME: J.D. LAZIK	(3) CLASSIFICATION CHANGED TO
DATE: 7/29/94	(4) CONTAINS NO INFO CLASSIFIED INFO
	(5) CONTAINS INFO
	(6) CLASSIFICATION CANCELED
	(7) CLASSIFIED INFO BRACKETED