

R

TO: Chief of Operations JOB: 884

FROM: Chief Project Engineer RE: Building 419, Gantry Crane

DATE: March 1, 1954

Attached is a letter from Crane Hoist Engineering Corp. covering their recommendation regarding the difficulties which have been experienced at the jobsite with the gantry crane, Building 419. It is requested that a requisition be written to cover the purchase of a new load brake which will be exchanged with the one installed in the present crane. This requisition should cover the repair and reshipment of the existing load brake to the jobsite.

BEST COPY AVAILABLE

Original signed by
 H. L. DIETZE

David L. Narver, Jr.
 Chief Project Engineer

DLNJr:HLD:cas
 Enc. 1

cc: Resident Engineer JS
 Constr.-Oper. Div.
 Project Engineering File
 751 Mail Room (2)

J. H. Manning

NATIONAL ARCHIVES
 REPOSITORY PACIFIC SOUTHWEST REGION
 COLLECTION R6 326 ATOMIC ENERGY COMMISSION
 BOX No. 199624 (#608) A16334 326-65V0170
 ELMER GENERAL
 FOLDER JOB 884 PROJECT ENGINEERING FILE