

FIVE ZERO CMM ELEVATION OF GROUND SURROUNDING STATION ONE FIVE FIVE ZERO IS APPROXIMATELY PLUS FIVE FEET PD BEDROCK UNDER STATION IS AT ELEVATION THREE PNT THREE FEET PD BOTTOM OF SLAB IS ELEVATION FIVE PNT THREE FEET PD BECAUSE OF POSSIBILITY OF UNDERCUTTING OF UNSTABLE MATERIAL WHICH HAS BEEN DISTURBED IN REMOVING OLD SANSTONE STATION AND EXCAVATING FOR PIPE TO WELL UNDER HIGH TIDE AND STORM CONDITIONS CMM WE HAVE APPROVED POURING TWO FEET PNT ZERO INCHES OF LEAN CONCRETE

TO GUARANTEE FOUNDATION STABILITY

10/0 STAGE REVIEW AUTOGRAPH TO THE ACCOUNT OF THE ACCOUNT OF